

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

October 17, 2016

Ms. Laura Bosinski  
Holland Central School District  
School Business Official / Treasurer  
103 Canada Street  
Holland, New York 14080

**Re: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Ms. Laura Bosinski

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Holland Central School District, including:

- Holland Elementary School, 173 Canada Street, Holland, NY

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than or equal to the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling were performed on 9/26/2016 and 9/27/2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".


As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based on the sampling and analysis performed, 3 sources of potable water in Holland Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Holland Central School District.

Sincerely,  
Stohl Environmental, LLC.



William K. Sisco  
Senior Project Manager



Derek Banach  
Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**Ms. Laura Bosinski  
Holland Central School District  
School Business Official / Treasurer  
103 Canada Street  
Holland, New York 14080**

**Prepared by:**



**ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES**

**4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219**

**☎ (716) 312-0070 📠 (716) 312-8092**

**[www.stohlenvironmental.com](http://www.stohlenvironmental.com)**

**Conditions as of September 26-27, 2016**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Holland Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Holland Elementary School, 173 Canada Street, Holland, NY

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Holland Elementary School. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

### Sampling Protocol:

In accordance with NYS regulations, *Subpart 67-4: Lead Testing in School Drinking Water*, and the EPA guidance document, *'3Ts for Reducing Lead in Drinking Water in Schools'*, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
  - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
  - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.2 Executive Summary of Sampling and Analysis:

First Draw Samples				Confirmatory Samples **		
Building Name	Total Number of Samples Collected	Number of Samples Analyzed Below the NYS Action level of 15 ppb	Number of Samples Analyzed above the NYS Action Level of 15 ppb	Total Number of Samples Collected	Number of Samples Analyzed Below the NYS Action level of 15 ppb	Number of Samples Analyzed Below the NYS Action level of 15 ppb
Holland Elementary School	124	121	3	0	0	0

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Locations of Samples Analyzed at or above the NYS Action Level of 15 parts per billion			
Sample #	Classroom or other Location	Outlet type	Laboratory Analysis
110.3-73	Room 23	Sink	15.8
110.3-84	Room 32	Sink	24.4
110.3-118	Japanese Garden (Right from Main Entry)	Hose Bib	236

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.4 Laboratory Analytical Reports by Building



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 11 rows of lead analysis data for various sample IDs (186516-001 to 186516-011).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and "Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:

Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186516-012 through 186516-022, all for Lead analysis using EPA 200.9 Rev 2.2 method. Results range from <5.00 to 10.5.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

# Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
Blasdell, NY 14219

**Order #:** 186516

**Matrix** Drinking Water  
**Received** 09/29/16  
**Reported** 10/07/16

**Attn:**

**Project:** Holland Elementary  
**Location:** 173 Canada Street Holland NY  
**Number:** 2016L-110.3

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
186516-023	110.3-23	RM 8 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-024	110.3-24	RM 8 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-025	110.3-25	RM 8 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-026	110.3-26	RM 9 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	7.30	5.00	µg/L	10/04/16	SA
186516-027	110.3-27	RM 9 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-028	110.3-28	RM 10 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-029	110.3-29	RM 10 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-030	110.3-30	RM 10 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/04/16	SA
186516-031	110.3-31	RM 11 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/05/16	SA
186516-032	110.3-32	RM 11 S					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/05/16	SA
186516-033	110.3-33	RM 11 B					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/05/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and "Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:

Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for Lead analysis across various sample IDs (186516-034 to 186516-044).

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (186516-045 to 186516-055) and parameters (Metals Analysis, Lead) with corresponding results and methods.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and "Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186516-056 through 186516-066, all showing Lead results <5.00.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186516-067 through 186516-077, all for Lead analysis using EPA 200.9 Rev 2.2 method.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 186516-078 through 186516-088 with corresponding lead analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (e.g., 186516-089) and locations (e.g., Girls Lav S, Boys Lav S) with corresponding results and reporting limits.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (186516-100 to 186516-110) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Attn:
Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include various sample IDs (186516-111 to 186516-121) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 186516

Attn:

Matrix: Drinking Water
Received: 09/29/16
Reported: 10/07/16

Project: Holland Elementary
Location: 173 Canada Street Holland NY
Number: 2016L-110 3

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains three rows of lead analysis results for samples 186516-122, 186516-123, and 186516-124.

186516-10/07/16 12:16 PM

Abisola O Kasali

Reviewed By: Abisola Kasali
Metals Supervisor

EPA Regulatory Limits

Table with columns: Parameter, Reg. Limit, Unit. Row for Lead with Reg. Limit 15.0 and Unit µg/L.

Certifications

Table with columns: Parameter, Method, Matrix, CA, CT, FL, NJ, NY, RI, VA. Row for Lead with 'X' marks under CA, CT, FL, NJ, NY, RI, VA.

Key

Table with columns: State, Regulatory Agency - Lab ID, Certificate Number. Lists states CA, CT, FL, NJ, NY, RI, VA and their corresponding agencies and certificate numbers.

'X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



**ENVIRONMENTAL CONSULTANTS**

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued September 22, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total

EPA 200.9 Rev. 2.2

Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES NON POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total  
EPA 200.7 Rev. 4.4  
EPA 6010C  
EPA 7000B  
EPA 200.9 Rev. 2.2

**Sample Preparation Methods**

EPA 3010A  
EPA 3005A  
EPA 3020A

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved analytes are listed below:*

**Characteristic Testing**

TCLP EPA 1311

**Polychlorinated Biphenyls**

PCB-1268 EPA 8082A

**Metals I**

**Sample Preparation Methods**

Barium, Total	EPA 6010C	EPA 3010A
Cadmium, Total	EPA 6010C	EPA 3050B
Chromium, Total	EPA 6010C	EPA 3550C
Lead, Total	EPA 6010C	EPA 3031
	EPA 7000B	
Nickel, Total	EPA 6010C	
Silver, Total	EPA 6010C	

**Metals II**

Antimony, Total	EPA 6010C
Arsenic, Total	EPA 6010C
Chromium VI	EPA 7196A
Mercury, Total	EPA 7471B
Selenium, Total	EPA 6010C

**Polychlorinated Biphenyls**

PCB-1016	EPA 8082A
PCB-1221	EPA 8082A
PCB-1232	EPA 8082A
PCB-1242	EPA 8082A
PCB-1248	EPA 8082A
PCB-1254	EPA 8082A
PCB-1260	EPA 8082A
PCB-1262	EPA 8082A

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MR. FAYEZ ABOUZAKI**  
**SCHNEIDER LABORATORIES GLOBAL, INC**  
**2512 WEST CARY STREET**  
**RICHMOND, VA 23220-5117**

**NY Lab Id No: 11413**

*is hereby APPROVED as an Environmental Laboratory for the category*  
**ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE**  
*All approved subcategories and/or analytes are listed below:*

**Miscellaneous**

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

**Sample Preparation Methods**

EPA 3050B

**Serial No.: 54669**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MR. FAYEZ ABOUZAKI**  
**SCHNEIDER LABORATORIES GLOBAL, INC**  
**2512 WEST CARY STREET**  
**RICHMOND, VA 23220-5117**

**NY Lab Id No: 11413**

*is hereby APPROVED as an Environmental Laboratory for the category*  
**ENVIRONMENTAL ANALYSES AIR AND EMISSIONS**  
*All approved subcategories and/or analytes are listed below:*

**Metals I**

Lead, Total                                NIOSH 7082  
                                                          40 CFR PART 50 1984 APP G

**Miscellaneous**

Fibers                                        NIOSH 7400 A RULES

**Serial No.: 54670**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.6 Chains of Custody



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8892  
 www.stohlenvironmental.com

STOHL Job # 2016L-110.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-1	Boiler Room	HB	2:14	0		
110.3-2	Boiler Room	HB	2:22	0		
110.3-3	RM 1	S	11:40	0		
110.3-4	RM 1	S	11:40	0		
110.3-5	RM 1	B	11:40	0		
110.3-6	RM 2	S	11:42	0		
110.3-7	RM 2	S	11:42	0		
110.3-8	RM 2	B	11:42	0		
110.3-9	RM 3	S	11:46	0		
110.3-10	RM 3	S	11:46	0		
110.3-11	RM 3	B	11:46	0		
110.3-12	RM 4	S	11:50	0		
110.3-13	RM 4	S	11:50	0		
110.3-14	RM 4	B	11:50	0		
110.3-15	RM 5	S	11:52	0		
110.3-16	RM 5	S	11:52	0		
110.3-17	RM 6	S	11:52	0		
110.3-18	RM 6	S	11:54	0		

186516 S 124

V:\186\186516

fghraizi 9/29/2016 2:45:00 PM  
 Federal Express 78420 1410981

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: ROSE ZAFFRANI Print Name Stohl Env: ROSE ZAFFRANI Date: 9/26/2016

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-110.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

*Turnaround*

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-19	RM 6	B	11:54	0		
110.3-20	RM 7	S	11:57	0		
110.3-21	RM 7	S	11:57	0		
110.3-22	RM 7	B	11:57	0		
110.3-23	RM 8	S	11:59	0		
110.3-24	RM 8	S	11:59	0		
110.3-25	RM 8	B	11:59	0		
110.3-26	RM 9	S	0:03	0		
110.3-27	RM 9	S	0:03	0		
110.3-28	RM 10	S	0:06	0		
110.3-29	RM 10	S	0:06	0		
110.3-30	RM 10	B	0:06	0		
110.3-31	RM 11	S	0:08	0		
110.3-32	RM 11	S	0:08	0		
110.3-33	RM 11	B	0:08	0		
110.3-34	RM 12	S	0:11	0		
110.3-35	RM 12	S	0:11	0		
110.3-36	RM 12	B	0:11	0		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Pete Z... Print Name Pete Z... Stohl Env: Pete Z... Date: 9/26/2016

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-110.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-37	Drinking Fountain	DF	0:14	LZS8WS_1F		
110.3-38	RM 13	S	0:16	0		
110.3-39	RM 13	S	0:16	0		
110.3-40	RM 13	B	0:16	0		
110.3-41	D 43	SS	0:18	0		
110.3-42	RM 14	B	0:20	0		
110.3-43	RM 14	S	0:20	0		
110.3-44	RM 14	S	0:20	0		
110.3-45	RM 15	S	0:25	0		
110.3-46	RM 15	S	0:25	0		
110.3-47	RM 15	B	0:25	0		
110.3-48	RM 16	S	0:29	0		
110.3-49	RM 17	S	0:31	0		
110.3-50	RM 17	B	0:31	0		
110.3-51	RM 17	S	0:31	0		
110.3-52	RM 18	S	0:34	0		
110.3-53	Jans. Closet	SS	0:38	0		
110.3-54	Unisex Restroom	S	0:40	0		

**Notes:**

Please e-mail lab results to labs@stohlenv.com

Sampled By: Pete Zarrum Print Name Pete Zarrum Stohl Env: Pete Zarrum Date: 9/26/2016

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-110.3

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLINDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8092  
www.stohlenvironmental.com

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

### LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-55	Unisex Bathroom	S	0:42	0		
110.3-56	Men's Room	S	0:45	0		
110.3-57	Men's Room	S	0:45	0		
110.3-58	Mens Room	S	0:45	0		
110.3-59	Drinking Fountain	DF	0:46	EHFSA8_1K		
110.3-60	Womens Room	S	0:48	0		
110.3-61	Womens Room	S	0:48	0		
110.3-62	Womens Room	S	0:48	0		
110.3-63	RM 19	S	0:51	0		
110.3-64	RM 19	B	0:51	0		
110.3-65	RM 20	S	0:52	0		
110.3-66	RM 20	B	0:52	0		
110.3-67	RM 21	S	0:55	0		
110.3-68	RM 21	B	0:56	0		
110.3-69	RM 22	S	0:58	0		
110.3-70	RM 22	B	0:58	0		
110.3-71	RM 24	S	1:00	0		
110.3-72	RM 24	B	1:00	0		

Notes:  
Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

Sampled By: PETE ZAFFRANI Print Name Stohl Env: PETE ZAFFRANI Date: 9/26/2016

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-110.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

*Turnaround*

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-73	RM 23	S	1:03	0		
110.3-74	RM 23	B	1:03	0		
110.3-75	RM 25	S	1:04	0		
110.3-76	RM 25	B	1:04	0		
110.3-77	RM 26	S	1:05	0		
110.3-78	RM 27	S	1:10	0		
110.3-79	RM 28	S	1:11	0		
110.3-80	RM 29	S	1:13	0		
110.3-81	RM 29	S	1:13	0		
110.3-82	RM 30	S	1:14	0		
110.3-83	RM 31	S	1:15	0		
110.3-84	RM 32	S	1:16	0		
110.3-85	RM 33	S	1:17	0		
110.3-86	RM 34	S	1:18	0		
110.3-87	RM 35	S	1:20	0		
110.3-88	Drinking Fountain	DF	1:22	LZS8WS_1F		
110.3-89	Girls Lav	S	1:23	0		
110.3-90	Girls Lav	S	1:23	0		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: PETE ZAFFRAN Print Name PETE ZAFFRAN Stohl Env: PETE ZAFFRAN Date: 9/26/2016

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14213  
☎ (716) 312-0070 ☎ (716) 312-4092  
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-110.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

### LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-91	Girls Lav	S	1:23	0		
110.3-92	Boys Lav	S	1:26	0		
110.3-93	Boys Lav	S	1:26	0		
110.3-94	Boys Lav	S	1:26	0		
110.3-95	Drinking Fountain	DF	1:30	HACFSCQ_1C		
110.3-96	Jans. Closet	SS	1:30	0		
110.3-97	Unisex Bathroom	S	1:32	0		
110.3-98	Boys Locker Room	S	1:37	0		
110.3-99	Girls Locker Room	S	1:37	0		
110.3-100	Custodians Office	S	1:40	0		
110.3-101	Music Room RM 56	S	1:43	0		
110.3-102	Drinking Fountain	DF	1:44	HCWC8ALMOND Vinyl		
110.3-103	Faculty Room	S	1:48	0		
110.3-104	Drinking Fountain	DF	1:48	EZFS8_1F		
110.3-105	RM 74	S	1:53	0		
110.3-106	RM 74	S	1:53	0		
110.3-107	Unisex Bathroom	S	1:56	0		
110.3-108	Unisex Bathroom	S	1:56	0		

### Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Pete Zarram Print Name Stohl Env: Pete Zarram Date: 9/26/2016

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-8079 ☎ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-110.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
110.3-109	Nurse Sink	S	1:58	0		
110.3-110	Nurse Bathroom	S	1:58	0		
110.3-111	Jans. Closet	SS	2:00	0		
110.3-112	Laundry RM	S	2:02	0		
110.3-113	Kitchen	S	2:05	0		
110.3-114	Kitchen	S	2:06	0		
110.3-115	Kitchen	S	2:07	0		
110.3-116	Kitchen	S	2:07	0		
110.3-117	Jap. garden	HB	2:25	0		
110.3-118	Jap. Garden	HB	2:30	0		
110.3-119	Exterior RM 13	HB	2:41	0		
110.3-120	Exterior RM 21	HB	2:43	0		
110.3-121	Exterior RM 24	HB	2:47	0		
110.3-122	Exterior RM 33	HB	2:49	0		
110.3-123	Exterior Band RM	HB	2:52	0		
110.3-124	Exterior Exit 8	HB	2:56	0		
				0		
				0		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: PETE ZAFFRANI Print Name Pete Zaffrani Stohl Env: Pete Zaffrani Date: 9/26/2016

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/27/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

